



**BUREAU
VERITAS**

Certificate of compliance

Applicant: Kostal Industrie Elektrik GmbH
Lange Eck 11
58099 Hagen
Germany

Product: Automatic disconnection device between a generator and the public low-voltage grid

Model: PLENTICORE BI 5.5/26,
PLENTICORE BI 10/26

Use in accordance with regulations:

Automatic disconnection device with three-phase mains surveillance in accordance with DIN V VDE V 0126-1-1/A1:2012-02 and DIN VDE V 0126-1-1:2013-08 for Battery Inverter systems with a three-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter. This serves as a replacement for the disconnection device with insulating function, which the distribution network provider can access at any time.

Applied rules and standards:

DIN V VDE V 0126-1-1/A1 (VDE V 0126-1-1/A1):2012-02

Automatic disconnection device between a generator and the public low-voltage grid; Amendment 1.

At the time of issue of this certificate, the representative product listed above corresponds to the stated rules and standards.

Report number: 19TH0374-BI-VDE0126_0 **Certification Program:** NSOP-0032-DEU-ZE-V01
Certificate number: U21-0515 **Date of issue:** 2021-06-10

Certification body



Thomas Lammel



Certification body Bureau Veritas Consumer Products Services Germany GmbH accredited according to DIN EN ISO/IEC 17065

A partial representation of the certificate requires the written approval of Bureau Veritas Consumer Products Services Germany GmbH